



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

June 18, 2008

ECOLOGICAL LABORATORIES INC.
BARRY RICHTER/ GAYLE RICHTER
13 HENDRICKSON AVENUE
LYNBROOK NY 11563

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE
Manufacturer: ECOLOGICAL LABORATORIES INC.
Product Name: MICROBE LIFT ADULT LIQUID BACTERIAL CULTURE
Model Number(s): NONE
Product File No: 20080058

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2013.

This approval supersedes the approval issued on June 9, 2003 under product file number 20080058.

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.
- Based on information supplied by the manufacturer and reviewed by this department, the approval for this product recognizes this septic tank additive will not adversely affect the user, the bacterial action in septic systems, the soil hydraulic conductivity in soil absorption areas, or groundwater quality, when used in accordance with the manufacturers instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
glen.schlueter@wi.gov **Email**
8:00AM – 4:30PM CDT **Work Hours**
GWS:gws